

Product information

Periphery module

E-Mess UI



E-Mess UI (3 voltage- and 4 current transformer inputs for L1-3 and N)



Qualified personnel

All devices described in this manual may only be used, built up and operated together with this documentation. Installation, initiation and operation of these devices might only be done by instructed personnel with certified skills, who can prove their ability to install and initiate electrical and mechanical devices, systems and current circuits in a generally accepted and admitted standard.

(valid from 12/2015)

Changes to older versions of this document

Changed in Rev. 02: CAN-process-image added

Changed in Rev. 03: CAN SDO description added, topology image replaced

Changed in Rev. 04: Offset 16-26: W → kW, VA → kVA, current transformer: "l" and "k" were mixed

Changed in Rev. 05: Hint for grounding prohibition ref. to DIN VDE 0100-557:2014-10


Changed in Rev. 06: Chapter Diagnostic-LEDs added

General wiring of E-Mess UI

- compact periphery module for measurement of current, voltage and calculation power and energy for L1, L2, L3
- Measurement of current in neutral wire
- **4 current transformer-pins** (in/out) ($I_{L1}, I_{L2}, I_{L3}, I_N$, max. 5A)
- **Current transformers must be potential separated and may not be grounded. *)**
- **Current transformers may not be wired in idle mode**
- including 8-pin connector with a bolt flange on each side cage clamp contact technology with 2,5mm²



- **4x voltage contacts** (in and out) for each of L1, L2, L3, N
- With compact and contact protected 4x2-pin connector with cage clamp 4mm² (2 pins per wire to combine wiring of multiple modules)



- 4x red / green **Diagnostic LEDs** (see chapter "Diagnostic LEDs")




Figure above: Description and wiring of all connections of E-MESS-UI-modules

***) At the connecting of measurement equipment via current transformer to the power circuit following instructions must be followed:**

- Secondary circuits of current transformers in low voltage systems may not be grounded, unless the measurement can be done by connecting to ground only.
- In secondary circuits of current transformers interrupting safety guards may not be used.
- Secondary conductors of transformers must be wired in that way, that no active parts can be touched by their isolation or cover, such as no contact with busbars.
- For connecting temporary measurements disconnecting terminals or shortcut clamps shall be provided.
- At the selection of current transformers the load by the secondary conductors (conductor cross section and length) must be considered.

Note:

- To reduce the influence of power resistors to the result of the measurement particularly transformer with a secondary rated current of .../1A shall be used.
- The voltage contact must be protected by short circuit protection equipment.
- The respective DIN VDE 0100-557:2014-10 contains the hint, that secondary circuits of current transformers may not be grounded in the low voltage facilities.


Technical data PM E-Mess UI

Technical data E-Mess-UI	
Operating temperature range	-20°C ... +60°C (without condens.)
Storage temperature range	-30°C ... +80°C
Dimensions W x H x D (mm)	20 x 108 x 70 mm
Weight	ca. 150 g
Connection technology	connector with cage clamp for cross sections up to 2,5mm ² (current) connector with cage clamp for cross sections up to 4mm ² (voltage)
Load voltage L+	24V DC (10V ... 30V DC, connected by device supply)
Protection class	I
Degree of pollution	2
Power frequency	50 Hz, 60Hz switchable


Voltage measurement	
3-Phase 4-Wire systems with rating voltage (L -N)	Up to 230V eff.
Overtoltage category	300V CAT III
Rated impulse voltage	4kV
Measurement range L-N	Up to max. 350V eff.
Impedance	1 MΩ / Phase
Resolution	0,1 V
Measurement precision (typ.)	0,5%
Sampling frequency	8 kHz

Curren measurement	
Rated current	1 / 5 A
Measurement range	0 - 6 A eff.
Impedance	14 mΩ
Resolution	0,1 A
Measurement precision (typ.)	0,5%
Sampling frequency	8 kHz

E-Mess topology – E-Mess- module integration



E-Mess sample topology – system net



(max. length between CPU and extension 30m, no separated potential!)

PM E-Mess-UI process data

The module occupies onboard 128 Byte in- and outputs in process image, only the lower 64 Byte of the input image will be synchronized with the process image at control point. The other process data are respective to the assignment accessible by direct periphery access.

As decentral periphery only the lower 64 Byte of the input process data will be transferred. Use SDO to access output data as well as input data on byte offset 64-128.

Process image inputs

Onboard (CPU CC3xxV): - in process image as far length of process image is configured properly
Decentral (DP3xxC) - mapped into TxPDOs

Offset	Function	Format	Unit
0	Voltage L1	uint16	0,1V _{eff}
2	Voltage L2	uint16	0,1V _{eff}
4	Voltage L3	uint16	0,1V _{eff}
6	Net frequenca	uint16	0,01 Hz
8	Current L1	uint16	0,1 A _{eff}
10	Current L2	uint16	0,1 A _{eff}
12	Current L3	uint16	0,1 A _{eff}
14	Current N	uint16	0,1 A _{eff}
16	Effective power L1	int16	0,1 kW
18	Effective power L2	int16	0,1 kW
20	Effective power L3	int16	0,1 kW
22	Apparent power L1	int16	0,1 kVA
24	Apparent power L2	int16	0,1 kVA
26	Apparent power L3	int16	0,1 kVA
28	Power factor (cos φ) L1	int16	0,1% (10 ⁻³)
30	Power factor (cos φ) L2	int16	0,1% (10 ⁻³)
32	Power factor (cos φ) L3	int16	0,1% (10 ⁻³)
34	Phase angle L1	int16	0,1°
36	Phase angle L2	int16	0,1°
38	Phase angle L3	int16	0,1°
40	Active energy L1	int32	0,1 kWh
44	Active energy L2	int32	0,1 kWh
48	Active energy L3	int32	0,1 kWh
52	Apparent energy L1	uint32	0,1 kVAh
56	Apparent energy L2	uint32	0,1 kVAh
60	Apparent energy L3	uint32	0,1 kVAh

Process image inputs

Onboard (CPU CC3xxV): only by direct periphery access

Offset	Function	Format	Unit
64...79	Reserved		
80	Tunnel state	uint16	
82	Tunnel ADE-register address	uint16	
84	Tunnel ADE-register data	uint16 / uint32	
88..95	Reserved		
96	Diagnostics / Condition bits (set by EMESS, cleared by reading L PEW) .0 Overcurrent L1 .1 L2 .2 L3 .3 Overvoltage L1 .4 L2 .5 L3 .6 Undervoltage L1 .7 L2 .8 L3 .9 Res. .10 Res. .11 Net frequency 0: 50Hz / 1:60 Hz .12 Res. .13 Phasing wrong .14 Res. .15 Data invalid:(compare with A96.15: if similar = setup ok if unsimilar = setup running	uint16	0,1 A _{eff}
98	Threshold overcurrent	uint16	0,1 A _{eff}
100	Threshold overvoltage	uint16	0,1 V _{eff}
102	Threshold undervoltage	int16	0,1 V _{eff}
104	Current transformer- transfer factor primary current	int16	
106	Current transformer- transfer factor secondary current	int16	
108	Current transformer- error correction transfer factor L1	int16	0,1% (10 ⁻³)
110	Current transformer- error correction transfer factor L2	int16	0,1% (10 ⁻³)
112	Current transformer- error correction transfer factor L3	int16	0,1% (10 ⁻³)
114	Current transformer- error correction transfer factor N	int16	0,1% (10 ⁻³)
116	Current transformer- error correction phase angle L1	int16	°min
118	Current transformer- error correction phase angle L2	int16	°min
120	Current transformer- error correction phase angle L3	int16	°min
122	Reserved (internal use)	uint16	
124	Reserved (internal use)	uint16	
126	Reserved (internal use)	uint16	

Process image outputs

Onboard (CPU CC3xxV): only by direct periphery access

Offset	Function	Format	Unit
0-38	Reserved		
40	Active energy L1	int32	0,1 kWh
44	Active energy L2	int32	0,1 kWh
48	Active energy L3	int32	0,1 kWh
52	Apparent energy L1	uint32	0,1 kVAh
56	Apparent energy L2	uint32	0,1 kVAh
60	Apparent energy L3	uint32	0,1 kVAh
64...79	Reserved		
80	Tunnel Command	uint16	
82	Tunnel ADE-register address	uint16	
84	Tunnel ADE-register data	uint16 / uint32	
88..95	Reserved		
96	Control bits: .010 Res. .11 Net frequency 0:50 / 1:60 Hz .1214 Res. .15 Setup -requirement (Bit toggeling) after writing of setup data in offset 98..120	uint16	
98	Threshold overcurrent	uint16	0,1 A _{eff}
100	Threshold overvoltage	uint16	0,1 V _{eff}
102	Threshold undervoltage	int16	0,1 V _{eff}
104	Current transformer- transfer factor primary current	int16	
106	Current transformer- transfer factor secondary current	int16	
108	Current transformer- error correction transfer factor L1	int16	0,1% (10 ⁻³)
110	Current transformer- error correction transfer factor L2	int16	0,1% (10 ⁻³)
112	Current transformer- error correction transfer factor L3	int16	0,1% (10 ⁻³)
114	Current transformer- error correction transfer factor N	int16	0,1% (10 ⁻³)
116	Current transformer- error correction phase angle L1	int16	°min
118	Current transformer- error correction phase angle L2	int16	°min
120	Current transformer- error correction phase angle L3	int16	°min
122	Reserved (internal use)	uint16	
124	Reserved (internal use)	uint16	
126	Reserved (internal use)	uint16	

Process data via SDO

Decentral (in DP3xxC) - via SDO (SFB114)

Every slot mapped to an object index, every parameter inside a slot module gets a subindex.

Configuration data:

Object index (hex)	Sub-index	Slot	Function	Format	Unit
3010	1	1	Control bits: .010 Res. .11 Net frequency 0:50 / 1:60 Hz .1215 Res. Setup requirement automatically after writing of last setup data at subindex 13	uint16	
3010	2	1	Threshold overcurrent	uint16	0,1 A _{eff}
3010	3	1	Threshold overvoltage	uint16	0,1 V _{eff}
3010	4	1	Threshold undervoltage	int16	0,1 V _{eff}
3010	5	1	Current transformer- transfer factor primary current	int16	
3010	6	1	Current transformer- transfer factor secondary current	int16	
3010	7	1	Current transformer- error correction transfer factor L1	int16	0,1% (10 ⁻³)
3010	8	1	Current transformer- error correction transfer factor L2	int16	0,1% (10 ⁻³)
3010	9	1	Current transformer- error correction transfer factor L3	int16	0,1% (10 ⁻³)
3010	10	1	Current transformer- error correction transfer factor N	int16	0,1% (10 ⁻³)
3010	11	1	Current transformer- error correction phase angle L1	int16	°min
3010	12	1	Current transformer- error correction phase angle L2	int16	°min
3010	13	1	Current transformer- error correction phase angle L3	int16	°min
3011	1..13	2	s. slot 1		
3012	1...13	3	s. slot 1		
3013	1..13	4	s. slot 1		
3014	1...13	5	s. slot 1		
3015	1..13	6	s. slot 1		
3016	1...13	7	s. slot 1		
3017	1..13	8	s. slot 1		
3018	1..13	9	s. slot 1		
3019	1..13	10	s. slot 1		
301A	1..13	11	s. slot 1		

Energy data:

Object index (hex)	Sub-index	Slot	Function	Format	Unit
3100	1	1	Active energy L1	int32	0,1 kWh
3100	2	1	Active energy L2	int32	0,1 kWh
3100	3	1	Active energy L3	int32	0,1 kWh
3100	4	1	Apparent energy L1	uint32	0,1 kVAh
3100	5	1	Apparent energy L2	uint32	0,1 kVAh
3100	6	1	Apparent energy L3	uint32	0,1 kVAh
3101	1..6	2	s. slot 1		
3102	1..6	3	s. slot 1		
3103	1..6	4	s. slot 1		
3104	1..6	5	s. slot 1		
3105	1..6	6	s. slot 1		
3106	1..6	7	s. slot 1		
3107	1..6	8	s. slot 1		
3108	1..6	9	s. slot 1		
3109	1..6	10	s. slot 1		
310A	1..6	11	s. slot 1		

Diagnostic and status bits:

Object index (hex)	Sub-index	Slot	Function	Format	Unit
3110	0	1	Diagnostics / Condition bits (set by EMESS, cleared by reading) .0 Overcurrent L1 .1 L2 .2 L3 .3 Overvoltage L1 .4 L2 .5 L3 .6 Undervoltage L1 .7 L2 .8 L3 .9 , 10 res. .11 Net frequency 0: 50Hz / 1:60 Hz .12 Res. .13 Phasing wrong .14 Res. .15 Setup activ (communication not allowed)		
3111	0	2	Diagnostic / status bits s slot 1
3112	0	3	Diagnostic / status bits s slot 1		
3113	0	4	Diagnostic / status bits s slot 1		
3114	0	5	Diagnostic / status bits s slot 1		
3115	0	6	Diagnostic / status bits s slot 1		
3116	0	7	Diagnostic / status bits s slot 1		
3117	0	8	Diagnostic / status bits s slot 1		
3118	0	9	Diagnostic / status bits s slot 1		
3119	0	10	Diagnostic / status bits s slot 1		
311A	0	11	Diagnose / Statusbits s Slot 1		

Diagnostic-LEDs

The diagnostic- and statusbits of process image inputs are mapped onto the diagnostic-LED's for faster error detection.

L1 – L3: one LED each phase

- red: common error L1 – L3 overvoltage or overcurrent
- green: all values in valid areas
- off: no voltage applied or undervoltage

- N:
 - red: phasing wrong
 - yellow: setup activ
 - green: normal operation („run“)

Qualified personnel

All devices described in this manual may only be used, built up and operated together with this documentation. Installation, initiation and operation of these devices might only be done by instructed personnel with certified skills, who can prove their ability to install and initiate electrical and mechanical devices, systems and current circuits in a generally accepted and admitted standard.

Copyright

This and all other documentation and software, supplied or hosted on INSEVIS web sites to download are copyrighted. Any duplicating of these data in any way without express approval by INSEVIS GmbH is not permitted. All property and copy rights of these documentation and software and every copy of it are reserved to INSEVIS GmbH.

Trade Marks

INSEVIS refers that all trade marks of particular companies used in own documentation are reserved trade marks are property of the particular owners and are subjected to common protection of trade marks.

Disclaimer

All technical details in this documentation were created by INSEVIS with highest diligence. Anyhow mistakes could not be excluded, so no responsibility is taken by INSEVIS for the complete correctness of this information. This documentation will reviewed regularly and necessary corrections will be done in next version.

With publication of this data all other versions are no longer valid.